File No. DTET-11099/31/2023-PRINCIPAL(POLY)-DTET (Computer No. 670064) 3074604/2023/O/o PRINCIPAL(POLY)(DTET)

Government of West Bengal CENTRAL CALCUTTA POLYTECHNIC 21, Convent Road, Kolkata – 700014

Memo No.CCP/Tender/2023/023

Date:30/01/2023

Tender Notice

Sealed quotation are invited by the Principal-in-Charge from different agencies/farms for repairing of pumps, installation of pipe lines and fixing of overhead tanks etc. of Central Calcutta Polytechnic as per the details as listed below-

Serial No.	Description of Works	Qty	Remarks
1	Repairing of Pump of Office Building	01	
2	Repairing of Pump of Old Building	01	
3	Installation of Overhead Tanks at Old Building		
4	Installation of suction and deliver pipe line for pump of Old Building	1000	
5	Fixing of Bib Tap and for urinals in the toilets and for basins.		
6	Repairing of Commodes Cisterns of the of the toilets.		

The Agencies/Farms are requested to submit their sealed quotation with all necessary documents duly self-attested photocopy of Aadhaar card, Voter Card, Pan Card, Trade License, Bank Details, any previous work credential if any and other relevant documents.

- 1) Office working hours:- 10.30 AM to 4.30 PM(Monday to Friday) &10.30 AM to 1.30 PM(Saturday) except Sundays & all Government Holidays
- 2) Last date & time of submission of quotation: 10 /02/2023(Friday) upto 4.30 P.M
- 3) Date and time of opening of quotation: 13/02/2023 (Monday) at 2 pm

The authority reserves the right to accept/reject any or all tenders without assigning any reason. Before submission of rate of quotation, interested Agencies/Farms must visit this Institute and will contact with Sri Anupam Mukherjee, Foreman Mechanical for checking and inspecting varies items like pumps, pipe lines etc. for getting an idea of the nature of work to be done. The agencies/farms are requested to be present at the time of opening of tender.

Principal In Charge Central Calcutta Polytechnic

Principal-in-Chrage CENTRAL CALCUTTA POLYTECHNIC (Govi. of West Bongal) 21, Convent Road, Kolkata-700 014